



# Declaration of Conformity

The submitted sample of the following equipment has been tested for CE marking according to the following European Directives LVD 2006/95/EC, It is possible to use CE marking to demonstrate the compliance with this LVD Directive.

**Applicant name & address** : Shenzhen Hpmont Technology Co., Ltd  
3F, Building 28, Wangjingkeng Industry Park, Xili Dakan,  
Nanshan District, Shenzhen, China

**Manufacturer & address** : Shenzhen Hpmont Technology Co., Ltd  
3F, Building 28, Wangjingkeng Industry Park, Xili Dakan,  
Nanshan District, Shenzhen, China

**Product** : Elevator Integrated Controller

**Model/Type reference** : HD5L-4T7P5, HD5L-4T011

**Trade mark** : HPMONT

**Ratings** : **Model: HD5L-4T7P5**  
Input: 3PH, 380-460Vac, 50/60Hz, 19A, 7.5kW  
Output: 3PH, 0-460Vac, 0-100Hz, 17A, 11kVA

**Model: HD5L-4T011**  
Input: 3PH, 380-460Vac, 50/60Hz, 28A, 11kW  
Output: 3PH, 0-460Vac, 0-100Hz, 25A, 16kVA

**Order No./ Report No.** : EASZG07240033/ EASZG07240033

Test Standards	
EN 61800-5-1:2007	Adjustable speed electrical power drive systems — Part 5-1: Safety requirements — Electrical, thermal and energy

This Declaration is for the exclusive use of CTI's Client and is provided pursuant to the agreement between CTI and its Client. The observations and test results referenced from this Declaration are relevant only to the sample tested. This Declaration by itself does not imply that the material, product, or service is or has ever been under an CTI certification program.

Note : This Declaration is part of the full test report(s) and should be read in conjunction with it.



Mild Hu

Lab Supervisor

Date: July 31, 2014